

"2015" Annual Drinking Water Quality Report

"Perquimans County Water"

Water System Number: "04-72-025"

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Richard Copeland at 252-426-8230. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings.**

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Name of Utility] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is wells that draw from the Yorktown Aquifer.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Perquimans County Water was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Bethel Long Well	Lower	June 2015
Bethel Plant Well	Moderate	June 2015
Winslow Well	Moderate	June 2015
Hurdle Well	Moderate	June 2015
Bethel Well # 2	Moderate	June 2015
Bethel Well # 3	Lower	June 2015
Winfall Plant Well	Moderate	June 2015
Lake Road Well	Moderate	June 2015
Chappell Deep Well	Moderate	June 2015
Chappell Shallow Well	Moderate	June 2015
Hunnicutt Well	Moderate	June 2015

The complete SWAP Assessment report for Perquimans County Water may be viewed on the Web at: www.ncwater.org/pws/swap. Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. We have implemented the following source water protection actions: All of our wellheads are above the 100 year flood plan, and are built to current EPA standards. You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.).

Violations that Your Water System Received for the Report Year

No violations detected 2015

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Tables of Detected Contaminants

Asbestos Contaminant

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Total Asbestos (MFL)	4-8-13	N	0.17			7	7	Decay of asbestos cement water mains; erosion of natural deposits

Unregulated Inorganic Contaminants

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
17-alpha-ethynylestradiol	7-8-14	<0.0009		
17-beta-estradiol	7-8-14	<0.0004		
4-androstene-3,17-dione	7-8-14	<0.0003		
Equilin	7-8-14	<0.004		
Estriol	7-8-14	<0.0008		
Estrone	7-8-14	<0.002		
Testosterone	7-8-14	<.00001		

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	May 2014	.198	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	May 2014	0	1	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Year Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)						N/A	80	Byproduct of drinking water disinfection
Location B01	2015	N	38	27	49			
B02	2015	N	46	33	57			
HAAS (ppb)						N/A	60	Byproduct of drinking water disinfection
Location B01	2015	N	15	11	21			
B02	2015	N	7	6	9			

For TTHM: *Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*

For HAAS: *Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.*


Consumer Confidence Report Certification Form

Water System Name: Perquimans County

Water System No.: 04 - 72 - 025 Report Year: 2015 Population Served: 9000

The Community Water System (CWS) named above hereby confirms that all provisions under 40 CFR parts 141 and 142 requiring the development of, distribution of, and notification of a consumer confidence report have been executed. Further, the CWS certifies the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency by their NC certified laboratory. In addition, if this report is being used to meet Tier 3 Public Notification requirements, as denoted by the checked box below, the CWS certifies that public notification has been provided to its consumers in accordance with the requirements of 40 CFR 141.204(d).

Certified by: Name: Richard Copeland Title: Supervisor

Signature: 

Phone #: 252-426-8230

Delivery Achieved Date: 5-3-16

Date Reported to State: 3-30-16

The CCR includes text which provides mandated Public Notice for a monitoring violation (check box, if yes)

Check **all** methods used for distribution (see instructions on back for delivery requirements and methods):

- Paper copy to all
- Notification of Availability of Paper Copy (other than in the CCR itself)
Notification Method _____ (i.e. US Mail, door hanger)
- Notification of CCR URL URL: www.perquimanscountync.gov
Notification Method on bill (i.e. on bill, bill stuffer, separate mailing, email)
- Direct email delivery of CCR (attached? ___ or embedded? ___)
Notification Method _____ (i.e. on bill, bill stuffer, separate mailing)
- Newspaper (attach copy) What Paper? _____ Date Published: _____
Notification Method _____ (i.e. US Mail, on bill, bill stuffer, door hanger, a postcard dedicated to the CCR, or email)
- "Good faith" efforts (in addition to the above required methods) were used to reach non-bill paying consumers such as industry employees, apartment tenants, etc. Extra efforts included the following methods:
 - posting the CCR on the Internet at URL: www.perquimanscountync.gov
 - mailing the CCR to postal patrons within the service area
 - advertising the availability of the CCR in news media (attach copy of announcement)
 - publication of the CCR in local newspaper (attach copy)
 - posting the CCR in public places such as: (attach list if needed) _____
 - delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers
 - delivery to community organizations such as: (attach list if needed)

Note: Use of social media (e.g., Twitter or Facebook) or automated phone calls do not meet existing CCR distribution methods under the Rule.